



STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE
04333-0016

JOHN ELIAS BALDACCI
GOVERNOR

DAVID A. COLE
COMMISSIONER

July 31, 2009

Mark Jarvinen, P.E.
Simpson Strong-Tie Company
5956 W. Las Positas Blvd.
Pleasanton, CA 94588

Subject: **EDOT EPOXY ADHESIVE**

Mr Jarvinen:

The Maine Department of Transportation's Concrete and Bridge Items Product Evaluation Committee has completed its review of the following product that was submitted by you for our consideration in December of 2008.

EDOT Epoxy Adhesive

MaineDOT Reference Number 08-60

The Committee has pre-qualified the use of this product on MaineDOT construction and maintenance projects. This product will be added to our Qualified Products List (QPL) of Anchoring Materials in the near future. MaineDOT project personnel may require pull-out testing prior to use on construction projects. This product is not approved for overhead anchoring or any application where the anchors will be under constant tension.

Also, a reminder that all Chemical Anchoring products require yearly re-certification to remain on the QPL. Please write or call with any questions; 207-624-3268.

Thank you for your interest in doing business with MaineDOT.

Sincerely,

Doug Gayne
Product Evaluation Coordinator

copy: Product File(s)



PRINTED ON RECYCLED PAPER