



Minnesota Department of Transportation

Office of Materials

Mail Stop 645
1400 Gervais Avenue
Maplewood, MN 55109-2044

Tel: 651/366-5592

Fax: 651/366-5461

March 3, 2009

(651) 366-5575

Mr. Ken Simpson
Simpson Strong-Tie Company, Inc.
Anchoring Systems Division
2600 International Street
Columbus, OH 43228

Re: Mn/DOT Approval for Simpson Strong-Tie's EDOT Epoxy

Dear Mr. Simpson:

The Minnesota Department of Transportation (Mn/DOT), Office of Materials and Road Research has reviewed the documentation you submitted for approval of Simpson Strong-Tie's EDOT epoxy. This product has been added to the "Mn/DOT Approved Concrete Anchorages" list. This approval is based on a minimum 3/8" diameter anchor with a minimum 3-3/8" embedment. This approval is also contingent upon satisfactory performance in the field.

Please note that it is the manufacturer's responsibility to immediately notify Mn/DOT of any product changes or modifications, or if the product is no longer being produced. If changes or modifications occur, without prior notification from the manufacturer, the product may be removed from the approved product list.

All of our approved products are located on the Mn/DOT Concrete web site at <http://www.dot.state.mn.us/products/index.html>.

If you have any questions or comments, please contact me at the above address.

Sincerely,

A handwritten signature in black ink, appearing to read "R. Mulvaney", written over a horizontal line.

Ronald Mulvaney, P.E.
Structural Concrete Engineer

Cc: File